



WESTLAKE ROYAL BUILDING PRODUCTS (USA) INC.

2801 Post Oak Blvd., Suite 600

Houston, Texas 77056

855-ROYAL85

www.westlakeroyalbuildingproducts.com

VINYL SIDING AND INSULATED VINYL SIDING

CSI Section: 07 46 33 Plastic Siding

1.0 RECOGNITION

Westlake Royal Building Products (USA) Inc., Vinyl Siding and Insulated Vinyl Siding described in this report were evaluated for use as exterior covering materials as part of the weather-resistant exterior wall envelope.

The exterior veneer, wind resistance, surface burning, fire-resistance, combustibility, thermal resistance, and installation properties of the siding were evaluated for compliance with the following codes:

- 2021, 2018, 2015, and 2012 International Building Code® (IBC)
- 2021, 2018, 2015, and 2012 International Residential Code® (IRC)
- 2021, 2018, 2015, and 2012 International Energy Conservation Code® (IECC)
- 2023 and 2020 Florida Building Code, Building (FBC, Building) – attached supplement
- 2023 and 2020 Florida Building Code, Residential (FBC, Residential)-attached supplement

The Vinyl Siding complies with the requirements for vinyl siding in 2021 and 2018 IBC Section 1404.14, or 2015 and 2012 IBC Section 1405.14. The Insulated Vinyl Siding is recognized as an alternative product under 2021 and 2018 IBC Section 1404, or 2015 and 2012 IBC Section 1405. The Vinyl Siding complies with the requirements of IRC Section R703.11. The Insulated Vinyl Siding complies with the requirements of 2021, 2018, and 2015 IRC Section R703.13.

2.0 LIMITATIONS

Use of the Westlake Royal Building Products (USA) Inc., siding recognized in this report is subject to the following limitations:

2.1 The siding shall be installed in accordance with the applicable code, ASTM D4756, the manufacturer’s published installation instructions, and this report. Where there is a conflict, the most restrictive requirements shall govern.

2.2 Flashing and a water-resistive barrier shall be installed as required by the applicable code.

2.3 The siding is manufactured in Woodbridge, Ontario, Canada, and Columbus, Ohio.

3.0 PRODUCT USE

Westlake Royal Building Products (USA) Inc., Vinyl Siding and Insulated Vinyl Siding are for use in Type V Construction and buildings constructed in accordance with the IRC. The siding does not exhibit sustained flaming when tested in accordance with NFPA 268 and may be used at a fire separation distance of 5 feet (1.52 m) or less in Construction Types I, II, III, and IV in accordance with 2021 and 2018 IBC Section 1405, or 2015 and 2012 IBC Section 1406.2.

Royal Brand and Exterior Portfolio Brand Vinyl Siding and Insulated Vinyl Siding was tested in accordance with ASTM E119 as part of a 1-hour fire-resistance-rated assembly and does not reduce the fire-resistance rating of code prescribed 1-hour fire-resistance-rated wall assemblies. The siding has a flame spread index of 25 or less and a smoke developed index of 450 or less when tested in accordance with ASTM E84.

3.1 Design: Building design wind pressures shall be determined in accordance with IBC Section 1609 or IRC Table R301.2(2) and modified for height and exposure in accordance with Table R301.2(3), using an effective wind area of 10 ft² (1 m²) as applicable. The allowable negative wind pressures for the Royal Brand Vinyl Siding, Exterior Portfolio Brand Vinyl Siding, Royal Brand Insulated Vinyl Siding, and Exterior Portfolio Brand Insulated Vinyl Siding are shown in Tables 1, 2, and 3 of this report for the 2021 IBC/IRC and Tables 4, 5, and 6 of this report for the 2018, 2015, and 2012 IBC/IRC. The allowable negative wind pressure for the model of siding selected shall exceed the components and cladding design wind pressures for the building on which it is used. The tabulated allowable pressures for the siding are applicable where the siding is applied directly over sheathing in accordance with IBC Section 2304.6 and substrates capable of independently resisting the full design wind pressures, both positive and negative, and fastened as described in the tables in this report.

The allowable pressures in this report shall not be used as tabulated when vinyl siding is installed solely over foam plastic sheathing as described in 2021 and 2018 IRC Section R703.11.2, or 2015 and 2012 IRC Sections R703.11.2.1 and R703.11.2.2. Vinyl Siding and Insulated Vinyl Siding may be used over foam plastic sheathing provided the allowable pressures are adjusted and the siding is installed in accordance with the conditions described in Section 3.2.1 of this report.

The product described in this Uniform Evaluation Service (UES) Report has been evaluated as an alternative material, design or method of construction in order to satisfy and comply with the intent of the provision of the code, as noted in this report, and for at least equivalence to that prescribed in the code in quality, strength, effectiveness, fire resistance, durability and safety, as applicable, in accordance with IBC Section 104.11. This document shall only be reproduced in its entirety.





3.2 Installation: Installation of Westlake Royal Building Products (USA) Inc. Vinyl Siding and Insulated Vinyl Siding shall be in accordance with the manufacturer’s published installation instructions, the applicable code, and this report.

The installation instructions and this report shall be available on the job site for quality control purposes during installation. Where installed over an approved backing capable of independently resisting the design wind pressure, the siding shall be installed in accordance with 2021 and 2018 IBC Section 1404.14; 2015 or 2012 IBC Section 1405.14; IRC Sections R703.3, R703.3.3, R703.11, and Table R703.3(1) (2012 IRC Table R703.4), as applicable; and the manufacturer’s instructions, using the fastening specifications in Tables 1, 2, 3, 4, 5, or 6 of this report.

The siding shall be installed over an approved water resistive barrier on walls flashed to prevent moisture intrusion and redirect it to the exterior. The siding joints shall overlap in accordance with the installation instructions to provide weather protection for the exterior walls. Protection against condensation in the wall assembly shall be provided in accordance with the applicable code. The siding shall be installed to allow movement of the siding panels due to temperature changes. The panels shall be fastened using corrosion-resistant fasteners at the maximum on-center spacing given in Tables 1, 2, 3, 4, 5, or 6 of this report, as applicable, to minimum 0.42-specific-gravity wood substrate or equivalent.

3.2.1 Installation of Vinyl Siding over Foam Plastic Sheathing:

3.2.1.1 Installation in Accordance with 2021 and 2018 IRC: Allowable wind pressure resistance for Vinyl Siding or Insulated Vinyl Siding installed solely over foam plastic sheathing shall not exceed the values tabulated in 2021 and 2018 IRC Table R703.11.2 for the corresponding wind speed and exposure category. The siding shall be installed in accordance with 2021 and 2018 IRC Section R703.11.

3.2.1.2 Installation of Vinyl Siding in Accordance with 2015 or 2012 IRC:

3.2.1.2.1 Prescriptive Installation for Wind Speeds Not Exceeding 115 mph (V_{ult}): Under the 2015 IRC where the wind speeds do not exceed 115 mph, Exposure B (90 mph, Exposure B under the 2012 IRC), Westlake Royal Building Products (USA) Inc. Vinyl Siding may be installed over foam plastic sheathing in accordance with IRC Section R703.11.2.1. Half-inch-thick (12.7 mm) gypsum wallboard shall be installed on the inside of the wall and fastened using minimum 0.120-inch-shank-diameter (3.05 mm) nails with minimum 0.313-inch-diameter (7.95 mm) heads spaced at maximum 16 inches on-center (406 mm) to penetrate minimum 1 1/4 inches (31.8 mm) into wood substrate.

3.2.1.2.2 Pressure Reductions for Wind Speeds Exceeding 115 mph (V_{ult}): For wind speeds exceeding 115 mph, Exposure B under the 2015 IRC (90 mph, Exposure B under the 2012 IRC), Westlake Royal Building Products (USA) Inc. Vinyl Siding may be installed over foam plastic sheathing in accordance with IRC Section R703.11.2.2. Fastening shall remain as specified in Tables 4 and 5 of this report for the model of siding selected, and the allowable wind pressures for the siding shall be reduced in accordance with 2015 or 2012 IRC Section R703.11.2.2 based on the wall assembly conditions listed therein.

4.0 PRODUCT DESCRIPTION


Westlake Royal Building Products (USA) Inc., Vinyl Siding is polyvinyl chloride (PVC) siding complying with ASTM D3679 as required by 2021 and 2018 IBC Section 1403.9, 2015 and 2012 IBC Section 1404.9, and IRC Section R703.11.

Westlake Royal Building Products (USA) Inc., Insulated Vinyl Siding is polyvinyl chloride (PVC) siding with a foam plastic backer complying with ASTM D7793 as required by 2021, 2018, and 2015 IRC Section R703.13. The Vinyl Siding with foam plastic backer provides a minimum R-value of 2.0.

The siding is available in various profiles for both horizontal and vertical installation and for use as soffit. The siding Brands, Product Families, and Styles are described in Tables 1 through 6 of this report. Various accessories such as flashing, corner moldings, and window trim are available for use with the siding products.

5.0 IDENTIFICATION

A label is affixed to the packaging and includes the Westlake Royal Building Products (USA) Inc. name or trademark, the manufacturer’s address, and the product model number. The packaging for the Vinyl Siding conforms to the requirements of ASTM D3679; the packaging and labeling for the Insulated Vinyl Siding conforms to the requirements of ASTM D7793. The label also includes the Evaluation Report Number (ER-432). Either IAPMO UES Mark of Conformity may also be used as shown below:



IAPMO UES ER-432



6.0 SUBSTANTIATING DATA

6.1 Reports of testing in accordance with ASTM D3679 and ASTM D7793 as required by ICC-ES Acceptance Criteria for Vinyl Siding (AC37). Approved February 2014, editorially revised January 2021.

6.2 Reports of testing in accordance with Section 3.3 of ICC-ES AC37 Approved February 2014, editorially revised January 2021 to determine an alternative pressure equalization factor for the insulated vinyl siding.

6.3 Reports of Surface Burning Characteristics testing in accordance with ASTM E84.

6.4 Reports of fire-resistance testing in accordance with ASTM E119.

6.5 Reports of ignitability testing in accordance with NFPA 268.

6.6 The manufacturer's quality control documentation.

6.7 Test reports are from laboratories in compliance with ISO/IEC 17025

7.0 STATEMENT OF RECOGNITION

This evaluation report describes the results of research completed by IAPMO Uniform Evaluation Service on Westlake Royal Building Products (USA) Inc. Vinyl Siding and Insulated Vinyl Siding to assess conformance to the codes shown in Section 1.0 of this report and serves as documentation of the product certification. The siding is produced at locations noted in Section 2.3 of this report under a quality control program with periodic inspection under the supervision of IAPMO UES.

For additional information about this evaluation report please visit www.uniform-es.org or email us at info@uniform-es.org



TABLE 1 — ROYAL BRAND VINYL SIDING

| Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) |
|------------------|--------------|-------------------------|-------------|---------------|----------------|---|------------------------------------|
| | | | | | | | 2021 IBC/IRC |
| Woodland | RWD45 | Double 4.5" Traditional | Horizontal | 9 | 0.046 | Standard ¹ /Staples ² | 73 |
| | RWD45D | Double 4.5" Designer | Horizontal | 9 | 0.046 | Standard ¹ /Staples ² | 80 |
| | RWBB | Board and Batten | Vertical | 7 | 0.046 | Standard ¹ /Staples ² | 60 |
| Estate | ESTD4 | Double 4" Traditional | Horizontal | 8 | 0.044 | Standard ¹ /Staples ² | 80 |
| | ESTD45D | Double 4.5" Designer | Horizontal | 9 | 0.044 | Standard ¹ /Staples ² | 80 |
| | ESTD5D | Double 5" Designer | Horizontal | 10 | 0.044 | Standard ¹ /Staples ² | 52 |
| | RCCOL6 | Single 6" Beaded | Horizontal | 6.5 | 0.044 | Standard ¹ /Staples ² | 93 |
| Residential | RED4 | Double 4" Traditional | Horizontal | 8 | 0.042 | Standard ¹ /Staples ² | 47 |
| | RED45 | Double 4.5" Traditional | Horizontal | 9 | 0.042 | Standard ¹ /Staples ² | 64 |
| | RED45D | Double 4.5" Designer | Horizontal | 9 | 0.042 | Standard ¹ /Staples ² | 64 |
| | RED5 | Double 5" Traditional | Horizontal | 10 | 0.042 | Standard ¹ /Staples ² | 47 |
| | RET3D | Triple 3" Traditional | Horizontal | 9 | 0.042 | Standard ¹ /Staples ² | 64 |
| Crest | RCD4 | Double 4" Traditional | Horizontal | 8 | 0.040 | Standard ¹ /Staples ² | 58 |
| | RCD4D | Double 4" Designer | Horizontal | 8 | 0.040 | Standard ¹ /Staples ² | 58 |
| | RCD45D | Double 4.5" Designer | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 53 |
| | RCD5 | Double 5" Traditional | Horizontal | 10 | 0.040 | Standard ¹ /Staples ² | 47 |
| | RCD5D2 | Double 5" Designer | Horizontal | 10 | 0.040 | Standard ¹ /Staples ² | 47 |
| | RCD4V10 | Vertical Double 4" | Vertical | 8 | 0.040 | Standard ¹ /Staples ² | 40 |
| | RC8 | Single 8" Traditional | Horizontal | 8 | 0.040 | Standard ¹ /Staples ² | 47 |
| Soffit as Siding | RSD5VSBF | Vertical Double 5" | Vertical | 10 | 0.042 | Standard ¹ /Staples ² | 29 |
| Genesis (Crest) | GEND45 | Double 4.5" Traditional | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 53 |
| | GEND45D | Double 4.5" Designer | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 53 |
| | GENT3 | Triple 3" Traditional | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 53 |

S.I. Units: 1 inch = 25.4 mm, 1 psf = 47.9 Pa

- For horizontal siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall be minimum 1½ inches in length and penetrate minimum 1¼ inches into wood substrate at maximum 16 inches on-center.
For vertical siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall penetrate a minimum of ½-inch into wood substrate at maximum 12 inches on-center.
- For horizontal siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall be minimum 1½ inches in length and penetrate minimum 1¼ inches into wood substrate at maximum 16 inches on-center.
For vertical siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall be minimum 1½ inches in length and penetrate minimum 1¼ inches into wood substrate at maximum 16 inches on-center.



TABLE 2 — EXTERIOR PORTFOLIO BRAND VINYL SIDING

| Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) |
|-------------------|---------------|-----------------------|-----------------------|------------------------------------|----------------|--|--|
| | | | | | | | 2021 IBC/IRC |
| Premium Point 360 | D4PPTM | Double 4" Traditional | Horizontal | 8 | 0.046 | Standard ¹ /Staple ² | 122 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 177 |
| | D45PPTM | Double 4.5" Dutchlap | Horizontal | 9 | 0.046 | Standard ¹ /Staple ² | 67 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 115 |
| | S55PPBB | Board and Batten | Vertical | 7 | 0.046 | Standard ¹ /Staple ² | 60 |
| | Market Square | D4STD | Double 4" Traditional | Horizontal | 8 | 0.044 | Standard ¹ /Staple ² |
| Horizontal | | | | Ring Nail with Washer ³ | | | 84 |
| D45DLSTD | | Double 4.5" Dutchlap | Horizontal | 9 | 0.044 | Standard ¹ /Staple ² | 82 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 111 |
| D5STD | | Double 5" Traditional | Horizontal | 10 | 0.044 | Standard ¹ /Staple ² | 55 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 84 |
| Carolina Sands | S65B | Single 6" Beaded | Horizontal | 6.5 | 0.044 | Standard ¹ /Staple ² | 49 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 89 |
| Parkview | D4CEDAR | Double 4" Traditional | Horizontal | 8 | 0.042 | Standard ¹ /Staple ² | 62 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 56 |
| | D4DCG | Double 4" Dutchlap | Horizontal | 8 | 0.042 | Standard ¹ /Staple ² | 62 |
| | | | Horizontal | | | Ring Nail with Washer | 56 |
| | D5CEDAR | Double 5" Traditional | Horizontal | 10 | 0.042 | Standard ¹ /Staple ² | 57 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 56 |
| | D5DCG | Double 5" Dutchlap | Horizontal | 10 | 0.042 | Standard ¹ /Staple ² | 57 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 56 |
| Elm Grove | D4EG | Double 4" | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 78 |
| | D4DLEG | Double 4" Dutchlap | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 80 |
| | D5DLEG | Double 5" Dutchlap | Horizontal | 10 | 0.040 | Standard ¹ /Staple ² | 78 |

(Table 2 continued on next page)



TABLE 2 — EXTERIOR PORTFOLIO BRAND VINYL SIDING (Continued)

| Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) |
|---------------------|--------------------|------------------------|-------------|---------------|--|--|------------------------------------|
| | | | | | | | 2021 IBC/IRC |
| American Dream Edge | D4 | Double 4" Traditional | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 80 |
| | D4DL | Double 4" Dutchlap | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 78 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 80 |
| | D5DL | Double 5" Dutchlap | Horizontal | 10 | 0.040 | Standard ¹ /Staple ² | 67 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 80 |
| | D4DLRO | Double 4" Dutchlap | Horizontal | 8 | 0.038 | Standard ¹ /Staple ² | 67 |
| D5DLRO | Double 5" Dutchlap | Horizontal | 10 | 0.038 | Standard ¹ /Staple ² | 80 | |
| Soffit as Siding | T4SS | Vertical Triple 4" | Vertical | 12 | 0.040 | Standard ¹ /Staple ² | 36 |
| | PPSS | Vertical Triple 3 1/3" | Vertical | 10 | 0.044 | Standard ¹ /Staple ² | 35 |
| | D5SA | Double 5" | Vertical | 10 | 0.038 | Standard ¹ /Staple ² | 53 |

S.I. Units: 1 inch = 25.4 mm, 1 psf = 47.9 Pa

1. For horizontal siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.
2. For vertical siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall penetrate a minimum of 1/2-inch into wood substrate at maximum 12 inches on-center.
3. For horizontal siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.
4. The Ring Nail with Washer is a 1 1/2" long, 1/8-inch shank diameter, 3/8" head diameter, ring-shank roofing nail with a 1/8 inch by 3/4-inch diameter fender washer. The fasteners shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.



TABLE 3 — INSULATED VINYL SIDING

| Brand | Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) | R Value |
|--------------------|----------------|--------------|---------------------------|-------------|---------------|----------------|---|------------------------------------|---------|
| | | | | | | | | 2021 IBC/IRC | |
| Royal | Haven | HAVD6 | Double 6" Traditional | Horizontal | 12 | 1.125 | Standard ¹ /Staples ² | 84 | 2.21 |
| | | HAVBB10 | Double 10" Board & Batten | Vertical | 20 | 1.125 | Standard ¹ /Staples ² | 44 | 2.08 |
| | | TMD7IP | Double 7" Traditional | Horizontal | 14 | 1.125 | Standard ¹ /Staples ² | 71 | 2.42 |
| Exterior Portfolio | CraneBoard | TMT6IP | Triple 6" Traditional | Horizontal | 18 | 1.125 | Standard ¹ /Staples ² | 58 | 2.21 |
| | | TMD7IP | Double 7" Traditional | Horizontal | 14 | 1.125 | Standard ¹ /Staples ² | 62 | 2.41 |
| | | D10BBIP | Double 10" Board & Batten | Vertical | 20 | 1.125 | Standard ¹ /Staples ² | 44 | 2.14 |
| | | TMQ4IP | Quad 4" Traditional | Horizontal | 16 | 1.125 | Standard ¹ /Staples ² | 51 | 2.57 |
| | | | | Horizontal | | | Ring Nail with Washer ³ | 69 | |
| | | TMQ45IP | Quad 4.5" Dutchlap | Horizontal | 18 | 1.125 | Standard ¹ /Staples ² | 51 | 2.74 |
| | | | | Horizontal | | | Ring Nail with Washer ³ | 51 | |

S.I. Units: 1 inch = 25.4 mm, 1 psf = 47.9 Pa

1. For horizontal siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall be minimum 2¹/₂ inches in length and penetrate minimum 1¹/₄ inches into wood substrate at maximum 16 inches on-center.
2. For vertical siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall penetrate a minimum of 1¹/₂-inch into wood substrate at maximum 12 inches on-center.
3. For horizontal siding- Staple fastening shall be minimum 16 gauge, 7¹/₁₆" crown staple. The staples shall penetrate minimum 1¹/₄ inches into wood substrate at maximum 16 inches on-center.
4. The Ring Nail with Washer is a 2¹/₂" long, 1¹/₈-inch shank diameter, 3¹/₈" head diameter, ring-shank roofing nail with a 1¹/₈ inch by 3¹/₈-inch diameter fender washer. The fasteners shall be minimum 1¹/₂ inches in length and penetrate minimum 1¹/₄ inches into wood substrate at maximum 16 inches on-center.



TABLE 4 — ROYAL BRAND VINYL SIDING

| Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) |
|------------------|--------------|-------------------------|-------------|---------------|----------------|---|------------------------------------|
| | | | | | | | 2018, 2015, 2012 IBC/IRC |
| Woodland | RWD45 | Double 4.5" Traditional | Horizontal | 9 | 0.046 | Standard ¹ /Staples ² | 102 |
| | RWD45D | Double 4.5" Designer | Horizontal | 9 | 0.046 | Standard ¹ /Staples ² | 111 |
| | RWBB | Board and Batten | Vertical | 7 | 0.046 | Standard ¹ /Staples ² | 83 |
| Estate | ESTD4 | Double 4" Traditional | Horizontal | 8 | 0.044 | Standard ¹ /Staples ² | 111 |
| | ESTD45D | Double 4.5" Designer | Horizontal | 9 | 0.044 | Standard ¹ /Staples ² | 111 |
| | ESTD5D | Double 5" Designer | Horizontal | 10 | 0.044 | Standard ¹ /Staples ² | 72 |
| | RCCOL6 | Single 6" Beaded | Horizontal | 6.5 | 0.044 | Standard ¹ /Staples ² | 130 |
| Residential | RED4 | Double 4" Traditional | Horizontal | 8 | 0.042 | Standard ¹ /Staples ² | 65 |
| | RED45 | Double 4.5" Traditional | Horizontal | 9 | 0.042 | Standard ¹ /Staples ² | 89 |
| | RED45D | Double 4.5" Designer | Horizontal | 9 | 0.042 | Standard ¹ /Staples ² | 89 |
| | RED5 | Double 5" Traditional | Horizontal | 10 | 0.042 | Standard ¹ /Staples ² | 65 |
| | RET3D | Triple 3" Traditional | Horizontal | 9 | 0.042 | Standard ¹ /Staples ² | 89 |
| Crest | RCD4 | Double 4" Traditional | Horizontal | 8 | 0.040 | Standard ¹ /Staples ² | 81 |
| | RCD4D | Double 4" Designer | Horizontal | 8 | 0.040 | Standard ¹ /Staples ² | 81 |
| | RCD45D | Double 4.5" Designer | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 74 |
| | RCD5 | Double 5" Traditional | Horizontal | 10 | 0.040 | Standard ¹ /Staples ² | 65 |
| | RCD5D2 | Double 5" Designer | Horizontal | 10 | 0.040 | Standard ¹ /Staples ² | 65 |
| | RCD4V10 | Vertical Double 4" | Vertical | 8 | 0.040 | Standard ¹ /Staples ² | 56 |
| | RC8 | Single 8" Traditional | Horizontal | 8 | 0.040 | Standard ¹ /Staples ² | 65 |
| Soffit as Siding | RSD5VSBF | Vertical Double 5" | Vertical | 10 | 0.042 | Standard ¹ /Staples ² | 40 |
| Genesis (Crest) | GEND45 | Double 4.5" Traditional | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 74 |
| | GEND45D | Double 4.5" Designer | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 74 |
| | GENT3 | Triple 3" Traditional | Horizontal | 9 | 0.040 | Standard ¹ /Staples ² | 74 |

S.I. Units: 1 inch = 25.4 mm, 1 psf = 47.9 Pa

- For horizontal siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall be minimum 1½ inches in length and penetrate minimum 1¼ inches into wood substrate at maximum 16 inches on-center.
For vertical siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall penetrate a minimum of ½-inch into wood substrate at maximum 12 inches on-center.
- For horizontal siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall be minimum 1½ inches in length and penetrate minimum 1¼ inches into wood substrate at maximum 16 inches on-center.
For vertical siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall be minimum 1½ inches in length and penetrate minimum 1¼ inches into wood substrate at maximum 16 inches on-center.



TABLE 5 — EXTERIOR PORTFOLIO BRAND VINYL SIDING

| Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) |
|-------------------|---------------|-----------------------|-----------------------|------------------------------------|----------------|--|--|
| | | | | | | | 2018, 2015, 2012 IBC/IRC |
| Premium Point 360 | D4PPTM | Double 4" Traditional | Horizontal | 8 | 0.046 | Standard ¹ /Staple ² | 170 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 246 |
| | D45PPTM | Double 4.5" Dutchlap | Horizontal | 9 | 0.046 | Standard ¹ /Staple ² | 93 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 159 |
| | S55PPBB | Board and Batten | Vertical | 7 | 0.046 | Standard ¹ /Staple ² | 83 |
| | Market Square | D4STD | Double 4" Traditional | Horizontal | 8 | 0.044 | Standard ¹ /Staple ² |
| Horizontal | | | | Ring Nail with Washer ³ | | | 117 |
| D45DLSTD | | Double 4.5" Dutchlap | Horizontal | 9 | 0.044 | Standard ¹ /Staple ² | 114 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 154 |
| D5STD | | Double 5" Traditional | Horizontal | 10 | 0.044 | Standard ¹ /Staple ² | 76 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 117 |
| Carolina Sands | S65B | Single 6" Beaded | Horizontal | 6.5 | 0.044 | Standard ¹ /Staple ² | 68 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 123 |
| Parkview | D4CEDAR | Double 4" Traditional | Horizontal | 8 | 0.042 | Standard ¹ /Staple ² | 86 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 77 |
| | D4DCG | Double 4" Dutchlap | Horizontal | 8 | 0.042 | Standard ¹ /Staple ² | 86 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 77 |
| | D5CEDAR | Double 5" Traditional | Horizontal | 10 | 0.042 | Standard ¹ /Staple ² | 79 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 77 |
| | D5DCG | Double 5" Dutchlap | Horizontal | 10 | 0.042 | Standard ¹ /Staple ² | 79 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 77 |
| Elm Grove | D4EG | Double 4" | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 109 |
| | D4DLEG | Double 4" Dutchlap | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 111 |
| | D5DLEG | Double 5" Dutchlap | Horizontal | 10 | 0.040 | Standard ¹ /Staple ² | 109 |

(Table 5 continued on next page)



TABLE 5 — EXTERIOR PORTFOLIO BRAND VINYL SIDING (Continued)

| Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) |
|---------------------|--------------------|------------------------|-------------|---------------|--|--|------------------------------------|
| | | | | | | | 2018, 2015, 2012 IBC/IRC |
| American Dream Edge | D4 | Double 4" Traditional | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 111 |
| | D4DL | Double 4" Dutchlap | Horizontal | 8 | 0.040 | Standard ¹ /Staple ² | 108 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 111 |
| | D5DL | Double 5" Dutchlap | Horizontal | 10 | 0.040 | Standard ¹ /Staple ² | 93 |
| | | | Horizontal | | | Ring Nail with Washer ³ | 111 |
| | D4DLRO | Double 4" Dutchlap | Horizontal | 8 | 0.038 | Standard ¹ /Staple ² | 93 |
| D5DLRO | Double 5" Dutchlap | Horizontal | 10 | 0.038 | Standard ¹ /Staple ² | 111 | |
| Soffit as Siding | T4SS | Vertical Triple 4" | Vertical | 12 | 0.040 | Standard ¹ /Staple ² | 49 |
| | PPSS | Vertical Triple 3 1/3" | Vertical | 10 | 0.044 | Standard ¹ /Staple ² | 49 |
| | D5SA | Double 5" | Vertical | 10 | 0.038 | Standard ¹ /Staple ² | 74 |

S.I. Units: 1 inch = 25.4 mm, 1 psf = 47.9 Pa

1. For horizontal siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.
2. For vertical siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall penetrate a minimum of 1/2-inch into wood substrate at maximum 12 inches on-center.
3. For horizontal siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.
4. The Ring Nail with Washer is a 1 1/2" long, 1/8-inch shank diameter, 3/8" head diameter, ring-shank roofing nail with a 1/8 inch by 3/4-inch diameter fender washer. The fasteners shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.



TABLE 6 — INSULATED VINYL SIDING

| Brand | Product Family | Product Code | Product Style | Orientation | Exposure (in) | Thickness (in) | Installation Method | Allowable Negative Wind Load (psf) | R Value |
|--------------------|------------------------------------|--------------|---------------------------|-------------|---------------|----------------|---|------------------------------------|---------|
| | | | | | | | | 2018, 2015, 2012 IBC/IRC | |
| Royal | Haven | HAVD6 | Double 6" Traditional | Horizontal | 12 | 1.125 | Standard ¹ /Staples ² | 67 | 2.21 |
| | | HAVBB10 | Double 10" Board & Batten | Vertical | 20 | 1.125 | Standard ¹ /Staples ² | 35 | 2.08 |
| | | TMD7IP | Double 7" Traditional | Horizontal | 14 | 1.125 | Standard ¹ /Staples ² | 56 | 2.42 |
| Exterior Portfolio | CraneBoard | TMT6IP | Triple 6" Traditional | Horizontal | 18 | 1.125 | Standard ¹ /Staples ² | 46 | 2.21 |
| | | TMD7IP | Double 7" Traditional | Horizontal | 14 | 1.125 | Standard ¹ /Staples ² | 60 | 2.41 |
| | | D10BBIP | Double 10" Board & Batten | Vertical | 20 | 1.125 | Standard ¹ /Staples ² | 35 | 2.14 |
| | | TMQ4IP | Quad 4" Traditional | Horizontal | 16 | 1.125 | Standard ¹ /Staples ² | 49 | 2.57 |
| | | | | Horizontal | | | Ring Nail with Washer ³ | | |
| | | TMQ45IP | Quad 4.5" Dutchlap | Horizontal | 18 | 1.125 | Standard ¹ /Staples ² | 49 | 2.74 |
| Horizontal | Ring Nail with Washer ³ | | | 66 | | | | | |

S.I. Units: 1 inch = 25.4 mm, 1 psf = 47.9 Pa

1. For horizontal siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall be minimum 2 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.
2. For vertical siding- Standard fastening shall be minimum 0.120-inch diameter, smooth-shank roofing nails with 0.438-inch diameter heads. The fasteners shall penetrate a minimum of 1 1/2-inch into wood substrate at maximum 12 inches on-center.
3. For horizontal siding- Staple fastening shall be minimum 16 gauge, 7/16" crown staple. The staples shall penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.
4. The Ring Nail with Washer is a 2 1/2" long, 1/8-inch shank diameter, 3/8" head diameter, ring-shank roofing nail with a 1/8 inch by 3/8-inch diameter fender washer. The fasteners shall be minimum 1 1/2 inches in length and penetrate minimum 1 1/4 inches into wood substrate at maximum 16 inches on-center.



FLORIDA SUPPLEMENT

WESTLAKE ROYAL BUILDING PRODUCTS (USA) INC.

2801 Post Oak Blvd., Suite 600

Houston, Texas 77056

855-ROYAL85

www.westlakeroyalbuildingproducts.com

VINYL SIDING AND INSULATED VINYL SIDING

CSI Section: 07 46 33 Plastic Siding

1.0 RECOGNITION

Westlake Royal Building Products (USA) Inc., Vinyl Siding and Insulated Vinyl Siding described in IAPMO UES Evaluation Report ER-432 are satisfactory alternatives to the cladding systems prescribed in the following codes:

- 2023 and 2020 Florida Building Code, Building (FBC, Building)
- 2023 and 2020 Florida Building Code, Residential (FBC, Residential)

2.0 LIMITATIONS

Use of the Westlake Royal Building Products (USA) Inc., siding recognized in this report supplement is subject to the following limitations:

2.1 Installation shall be in accordance with ER-432, the manufacturer's published installation instructions, and Section 1405 of the FBC, Building or Section R703 of the FBC, Residential, as applicable. Flashing shall comply with Section 1405.4 of the FBC, Building.

2.2 For buildings built in accordance with the FBC, Residential, design wind loads for cladding shall be determined in accordance with Tables R301.2(2) and R301.2(3), as required by Section R301.2.1 of the FBC, Residential; when required, conversion between V_{ult} (Ultimate Design Wind Speed) and V_{asd} (Nominal Design Wind Speed) shall be in accordance with R301.2.1.3 of the FBC, Residential. For buildings built in accordance with the FBC, Building, design wind loads for cladding shall be determined in accordance with Section 1609.1.1 of the FBC, Building; when required, conversion between V_{ult} and V_{asd} shall be in accordance with 1609.3.1 of the FBC, Building. Allowable design pressures determined in accordance with the FBC shall not exceed those in Tables 1, 2, or 3 of ER-432, as applicable.

2.3 Use of the Westlake Royal Building Products (USA) Inc., Vinyl Siding and Insulated Vinyl Siding for compliance with the high-velocity hurricane zone provisions of the FBC, Building and FBC, Residential, is outside the scope of this evaluation report.

2.4 For products falling under Florida Rule 61G20-3.008, verification is required that the report holder's quality assurance program is audited by a quality assurance entity, approved by the Florida Building Commission (or the building official when the report holder does not possess an approval by the Commission), to provide oversight and determine that the products are being manufactured as described in this evaluation report to establish continual product performance.

2.5 This supplement expires concurrently with ER-432.

For additional information about this evaluation report please visit www.uniform-es.org or email us at info@uniform-es.org